



Uždaroji akcinė bendrovė

Įmonės kodas 303287697, PVM mokėtojo kodas LT100008526416

Kalvarijų g. 125 korp. 3, LT-08221 Vilnius, Lietuva

Tel. +370-680-90900, +370-653-88885

el. p. ledmada@gmail.com, web: www.ledmada.lt

Sąskaita LT947300010138949797, bankas „Swedbank“ AB, Vilnius SWIFT: HABA LT 22

DECLARATION OF CONFORMITY EU

Supplier/manufacturer: UAB „Ledmada”
Address: Kalvariju g. 125, k. 3, LT-08221 Vilnius, Lithuania
Product name: LED High Bay Light (UFO type)
Product model: UF-050-XXX, UF-060-XXX, UF-070-XXX, UF-075-XXX
UF-080-XXX, UF-085-XXX, UF-090-XXX, UF-100-XXX
UF-120-XXX, UF-150-XXX, UF-180-XXX, UF-200-XXX
(XXX=PRO/STD/ECO)

We hereby declare that the above-mentioned product is in conformity with the basic safety requirements of EU directive:

LVD Directive 2014/35/EU

The following standards have been applied:
EN IEC 60598-1:2024+A11:2024
EN 60598-2-5:2015

EMC Directive 2014/30/EU

The following standards have been applied:
EN IEC 55015:2019+A11:2020
EN IEC 61000-3-2: 2019+A1:2021+A2:2024
EN 61000-3-3: 2013+A2:2021+AC:2022
EN IEC 61547:2023

RoHS Directive (EU) 2015/863 amending Annex II to Directive 2011/65/EU

The following standards have been applied:
IEC 62321-1:2013; IEC 62321-3-1:2013
IEC 62321-4:2013+A1:2017; IEC 62321-5:2013
IEC 62321-6:2015; IEC 62321-7-1:2015
IEC 62321-7-2:2017; IEC 62321-8:2017

Fire hazard testing (Glow-wire method)

The following standards have been applied:
IEC 60695-2-10:2021; IEC 60695-2-11:2021
IEC 60695-2-12:2021

Technical data:

Rated voltage 230/240VAC, rated frequency 50/60Hz, class of protection against electric shock I, IP65, IK08.

Vilnius, 2025-08-01

(place and date of issue)

UAB „Ledmada”

Director

Sergejus Sudzilovskis